

To, The Principal

North East Global School

Sub:- Water quality report.

Ref No. NEGS/RS/Health. Eng. Dept/2019-20/01

Dr:- 15/6/2020

Sir,
With reference to the subject cited above, I have the honour to provide water quality report of 1 Nos. of samples received by DLL for Chemical and Bacteriological Tests, the result of which follows :-

DISTRICT LEVEL WATER TESTING LABORATORY (PHE)
DHUBRI DIVISION : DHUBRI
DRINKING WATER TESTING REPORT

Date of Testing :-

18/6/20

PINPOINT LOCATION	Type of source	Parameters	pH	Turbidity (NTU)	Iron (mg/lit)	Fluoride (mg/lit)	Total Hardness (mg/lit)	Chloride (mg/lit)	Ca. Hardness (mg/lit)	Mg. Hardness (mg/lit)	Alkalinity (mg/lit)	Bacteria	Remarks
North West Global School	Bore well	Acceptable Limit	6.5	0	0.30	1.00	300	250	75	30	200	Absent	As per the performed test, the water sample is found to be fit for drinking purpose.
		Permissible Limit	8.5	5	1.00	1.50	600	1000	200	100	600	Absent	

N.B:- (i) Results are as per received sample complies IS-10500-2012
(ii) it is necessary to test Water Sources twice a year (particularly before and after monsoon)

COUNTERSIGNED

Asstt Executive Engineer (PHE)
Dhubri Sub-Division, Dhubri

Asstt Chemist (PHE)
DLL DHUBRI